



Load Test Report

Customer	RLC		
Date	2021 JAN 28		
Engine Model #	mtu12v1600g20s		
Engine Serial #	16701003591		
Engine Hours	32742		
Generator Make			
Generator Model #			
Generator Serial #			
Frame			
Standby	KW	KVA	Amps
Volts _480			
Continuous	KW	KVA	Amps
	550	687	826
Oil Pressure	Cold	Hot	
Idle	86	78	
1800 RPM	100	87	
Test Report			
Time Min	20 min	20 min	
Amps	390	628	
KW	325	524	
Fuel liters			