



Load Test Report

Customer		RLC Aggregate Equ	
Date		01-28-2021	
Engine Model #		2005 C-15	
Engine Serial #		BEM05085	
Engine Hours		863	
Generator Make			
Generator Model #			
Generator Serial #			
Frame			
Standby	KW	KVA	Amps
Volts 480			
Continuous	KW	KVA	Amps
	375	469	563
Oil Pressure			
	Cold	Hot	
Idle	52	46	
1800 RPM		70	
Test Report			
Time Min	30 min	30 min	
Amps	563	675	
KW	375	450	
Fuel liters			