



# Load Test Report

Customer		RLC Aggregate Equ	
Date		Jan 28 2021	
Engine Model #		3406	
Engine Serial #		1LS01460	
Engine Hours			
Generator Make			
Generator Model #			
Generator Serial #			
Frame			
Standby	KW	KVA	Amps
Volts 480			
Continuous	KW	KVA	Amps
	440	550	662
Oil Pressure	Cold	Hot	
Idle		52	
1800 RPM		60	
Test Report			
Time Min	30 min		
Amps	400		
KW	450		
Fuel liters			